

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Floodlight

Name and address of the applicant

BSI Aydınlatma Elektrik Elektronik San. ve Tic. A.Ş.
Konutkent Mah. 3029 Cad. No:3/91 Azel Urhan Tower 06810 Çankaya/Ankara
Turkey

Name and address of the manufacturer

BSI Aydınlatma Elektrik Elektronik San. ve Tic. A.Ş.
Konutkent Mah. 3029 Cad. No:3/91 Azel Urhan Tower 06810 Çankaya/Ankara
Turkey

Name and address of the factory

Note: When more than one factory, please report on page 2

☐ Additional information on page 2BSI Aydınlatma Elektrik Elektronik San. ve Tic. A.Ş.
Konutkent Mah. 3029 Cad. No:3/91 Azel Urhan Tower 06810 Çankaya/Ankara
Turkey

Ratings and principal characteristics

220-240Vac, 50/60Hz, IP66, Ta:55°C, 12 to 120.5W (see page 2 for details)

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

FL9222, FL9224, FL9226, FL9228, FL9230, FL9232, FL9234

Additional information (if necessary may also be reported on page 2)

☒ Additional information on page 2

BEAB Ref: LUM 0356

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014, IEC 60598-1:2014/AMD1:2017, IEC 60598-2-5:2015

National differences:

AT, BE, BG, CH, CY, CZ, DE, EE, ES, FI, FR, GB, GR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR

As shown in the Test Report Ref. No. which forms part of this Certificate

202100225TUR-001

This CB Test Certificate is issued by the National Certification Body

Intertek Testing & Certification Ltd.
Intertek House, Cleeve Road, Leatherhead, Surrey KT22 7SA, United Kingdom

Date: 2021-07-28

Signature: Peter Davies

page 1 of 2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Additional information

This test report also covers models listed below:

Model	Rated Power (W)	Lumen Output (lm) 3000K/4000K	Colour Temperature	A(mm)	B(mm)	C(mm)	H(mm)	F(mm)
FL9222	12	1320/1440	3000K/4000K	127	108	130	210	80
FL9224	24	2460/2880	3000K/4000K	127	108	130	210	80
FL9226	36	3940/4320	3000K/4000K	190	160	197	300	120
FL9228	48	5280/5760	3000K/4000K	190	160	197	300	120
FL9230	72	7290/8640	3000K/4000K	238	200	240	365	150
FL9232	108	11880/12960	3000K/4000K	238	200	240	365	150
FL9234	120.5	15840/17280	3000K/4000K	238	200	240	365	150

This CB Test Certificate is issued by the National Certification Body

Intertek Testing & Certification Ltd.
Intertek House, Cleeve Road, Leatherhead, Surrey KT22 7SA, United Kingdom



Date: 2021-07-28

Signature: Peter Davies

page 2 of 2